

SPECIFICATION

AV54R


AV54R Suggested Specification:

Round supply grilles shall be Tuttle and Bailey model AV54R. Grilles shall provide airflow as specified on plans. Installed units shall blend in with architectural style and not be obtrusive. Grilles shall be furnished with a rolled margin capable of being mounted directly to either a finished wall or exposed spiral duct. Nozzle grilles shall not be accepted.

The grilles shall be capable of blade deflections between 0° and 45° perpendicular and parallel to the mounting surface to accommodate various types of room layouts as required.

Grille construction shall consist of heavy gauge aluminum. The grille shall employ individually adjustable blade tensioners to hold the grille setting under normal operating and installation conditions.

The finish shall be either mill (ML) or Tuttle and Bailey white (WH).



Example: AV54R - 08 - SF - WH

*Only available in SF margin.