

Tellow Bailey

Submittal Drawing

- Constructed from galvanized steel Standard nominal lengths are 24, 36, 48, and 60 inches
- Optional internal insulation (does not include endcaps)
- Optional factory mounted cable operated damper





Standard Inlet Sizes	Α
6	5 7/16
8	7 7/16
10	9 7/16
12	11 7/16

Margin Style	End Fabrication	L
A, B, C,	ECP, ECL/R	N - 7/8
A, B, C, N, S, T	INT, FECP	N - 1/4
F, G	ALL TYPES	N - 1/4

F, G	AL	N - 1/4	
Margin Style		Inlet Size	Н
		6", 8"	10 5/8
A, B, C, N, S, T	10"	12 5/8	
0, 1		12"	14 5/8
		6", 8"	11
F, G		10"	13
		12"	15

01-4	\A/: -	141
Slot	VVIC	atns

1/2" 1" 3/4" 1 1/2"

Standard Lengths

36" 24" 48" 60" 72"

Standard Inlets

10 12

Options

Insulation

Margin Style

Dimensions in inches

В С F Ğ Ν

End Fabrication

ECP ECL / ECR INT **FECP**

N.4 a marina						W			
Margin Style	Slot Width	Number of Slots							
Ciyio		1	2	3	4	5	6	7	8
	1/2	1 7/16	2 11/16	3 15/16	5 3/16	6 7/16	7 11/16	8 15/16	10 3/16
A D N C	3/4	1 11/16	3 3/16	4 11/16	6 3/16	7 11/16	9 3/16	10 11/16	12 3/16
A, B, N, S,	1	1 15/16	3 11/16	5 7/16	7 3/16	8 15/16	10 11/16	12 7/16	14 3/16
	1 1/2	2 7/16	4 11/16	6 15/16	9 3/16	11 7/16	13 11/16	15 15/16	18 3/16
	2	2 15/16	5 11/16	8 7/16	11 3/16	13 15/16	16 11/16	19 7/16	22 3/16
	1/2	2 3/16	3 7/16	4 11/16	5 15/16	7 3/16	8 7/16	9 11/16	10 15/16
	3/4	2 7/16	3 15/16	5 7/16	6 15/16	8 7/16	9 15/16	11 7/16	12 15/16
C, F, G	1	2 11/16	4 7/16	6 3/16	7 15/16	9 11/16	11 7/16	13 3/16	14 15/16
	1 1/2	3 3/16	5 7/16	7 11/16	9 15/16	12 3/16	14 17/16	16 11/16	18 15/16
	2	3 11/16	6 7/16	9 3/16	11 15/16	14 11/16	17 7/16	20 3/16	22 15/16

Job:	Tag:		LP
Architect:	Submitted By:		6000 Plenum with Round Inlets
Engineer:			with Round inlets
Contractor:	SD - 2309	Rev: A (10/18)	

Ta Tuttle & Bailey®

Submittal Drawing

Cable Operated Damper (COD) Accessory Damper is **Factory Mounted** to Round Plenum Inlet Nominal Inlet Size - 1/4" Heavy Duty Braided Steel Cable is used Cable is operated to adjust Damper and stows in Plenum with standard flat-head or Diffuser when not in use screwdriver Dimensions in inches Tag: Job:_ LP Location:_ 6000 Plenum Submitted By: Architect: with Round Inlets Engineer:_ Contractor: SD - 2309 Rev: A (10/18)