
★ Tuttle & Bailey®

Submittal **Drawing**

- 20 gauge galvanized steel construction (optional 316 stainless steel)
- Slip inlet and outlet duct connections accept industry standard sizes
- Orifice ring flow sensor (requires 2 ½ equivalent duct diameters of straight duct upstream of the sensor)
- 90° damper with solid stainless steel shaft with position indicator
- No maintenance Teflon bearings
- Galvanized unit has galvanized damper blade and seal
- Stainless steel unit has stainless steel damper blade and NO seal
- Continuous seam weld
- No Insulation options



Control Mounting Bracket (Standard)

Size	Max CFM	L	Α
6	590	16	12
7	800	16	12
8	1045	16	12
10	1635	19 1/2	13 1/4
12	2350	20 1/2	13 1/4
14	3200	23	14.5

Galvanized Steel 316 Stainless Steel

NEMA 1 Control Enclosure Dust Tight Seal on Control Enclosure Controls Disconnect 24V Transformer Primary Voltage

120V 208V 240V 277V

Job:	Submitted By:		RRV
Location:			Exhaust Terminal Unit
Architect:			Slip / Slip Connections
Engineer:			Orifice Sensor
Contractor:	SD-7106	Rev: B (03/17)	